

120kW demand meter $\rightarrow I_{\text{avg over 30 min}}$

Bill for

Homeowner: 920 kW-hr \approx MW-hr

27-2

minimum charge: N.R.E. 5.00

with slide

First 100 kW.h @ 5¢

next 200 kW.h @ 3¢

remainder $(920 - 300) = 620 @ 2¢$

slide rate

5.00

6.00

12.40

\$ 28.40

surcharge
infrastructure